

Outdoor unit	RZAG100N7V1B		
Indoor unit	FAA100BUV1B		
<b>Function</b>			
Kühlung	Ja		
Heizen	Ja		
	Average (mandatory) Warmer (if designated) Colder (if designated)		
<b>Element</b>	<b>Symbol</b>	<b>Wert</b>	<b>Maßeinheit</b>
<b>Design Load</b>			
Kühlung	Pdesignc	9.50	kW
heating / Average	Pdesignh	7.80	kW
heating / Warmer	Pdesignh	4.46	kW
heating / Colder	Pdesignh	3.43	kW
<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj</b>			
Tj = 35°C	Pdc	9.50	kW
Tj = 30°C	Pdc	7.03	kW
Tj = 25°C	Pdc	4.46	kW
Tj = 20°C	Pdc	3.43	kW
<b>Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7°C	Pdh	6.86	kW
Tj = 2°C	Pdh	4.21	kW
Tj = 7°C	Pdh	2.73	kW
Tj = 12°C	Pdh	2.47	kW
Tj = Bivalent temperature	Pdh	7.80	kW
Tj = operating limit	Pdh	7.80	kW
<b>Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = 2°C	Pdh		kW
Tj = 7°C	Pdh		kW
Tj = 12°C	Pdh		kW
Tj = Bivalent temperature	Pdh		kW
Tj = operating limit	Pdh		kW
<b>Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7°C	Pdh		kW
Tj = 2°C	Pdh		kW
Tj = 7°C	Pdh		kW
Tj = 12°C	Pdh		kW
Tj = Bivalent temperature	Pdh		kW
Tj = operating limit	Pdh		kW
<b>Bivalent temperature</b>			
heating / Average	Tbiv	-10	°C
heating / Warmer	Tbiv	°C	°C
heating / Colder	Tbiv	°C	°C
<b>Cycling interval capacity</b>			
for cooling	Pcyc		kW
for heating	Pcych		kW
Degradation co-efficient cooling**	Cdc	0.25	-
<b>Electric power input in power models other than 'active mode'</b>			
Off mode	Poff	0.009	kW
Standby mode	Psb	0.009	kW
Thermostat-off mode	PTO	0.013	kW
Crankcase heater mode	PCK	0	kW
<b>Capacity control</b>			
Fest	N		
Gestaffelt	N		
Variable	N		
<b>Contact details for obtaining more information</b>	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium		

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

\*\* if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.