

Außengerät		BXA20A5V1B9					
Innengerät		FTXA20A2V1BW					
Function				Heating season			
Kühlung		Ja		Average (mandatory)		Ja	
Heizen		Ja		Warmer (if designated)		Ja	
				Colder (if designated)		Nein	
Element		Symbol		Wert		Gerät	
Design Load				Seasonal efficiency			
Kühlung		P _{designc}		2.00		kW	
heating / Average		P _{designh}		2.40		kW	
heating / Warmer		P _{designh}		1.75		kW	
heating / Colder		P _{designh}				kW	
				Kühlung		SEER	
				heating / Average		SCOP / A	
				heating / Warmer		SCOP / W	
				heating / Colder		SCOP / C	
Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J				Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J			
T _J = 35 °C		P _{dc}		2.00		kW	
T _J = 30 °C		P _{dc}		1.47		kW	
T _J = 25 °C		P _{dc}		0.95		kW	
T _J = 20 °C		P _{dc}		1.27		kW	
				T _J = 35 °C		EERd	
				T _J = 30 °C		EERd	
				T _J = 25 °C		EERd	
				T _J = 20 °C		EERd	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C		P _{dh}		2.12		kW	
T _J = 2 °C		P _{dh}		1.29		kW	
T _J = 7 °C		P _{dh}		0.92		kW	
T _J = 12 °C		P _{dh}		1.10		kW	
T _J = Bivalent temperature		P _{dh}		2.12		kW	
T _J = operating limit		P _{dh}		2.31		kW	
				T _J = -7 °C		COPd	
				T _J = 2 °C		COPd	
				T _J = 7 °C		COPd	
				T _J = 12 °C		COPd	
				T _J = Bivalent temperature		COPd	
				T _J = operating limit		COPd	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = 2 °C		P _{dh}		1.75		kW	
T _J = 7 °C		P _{dh}		1.16		kW	
T _J = 12 °C		P _{dh}		1.10		kW	
T _J = Bivalent temperature		P _{dh}		1.75		kW	
T _J = operating limit		P _{dh}		2.31		kW	
				T _J = 2 °C		COPd	
				T _J = 7 °C		COPd	
				T _J = 12 °C		COPd	
				T _J = Bivalent temperature		COPd	
				T _J = operating limit		COPd	
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C		P _{dh}				kW	
T _J = 2 °C		P _{dh}				kW	
T _J = 7 °C		P _{dh}				kW	
T _J = 12 °C		P _{dh}				kW	
T _J = Bivalent temperature		P _{dh}				kW	
T _J = operating limit		P _{dh}				kW	
T _J = -15 °C		P _{dh}				kW	
				T _J = -7 °C		COPd	
				T _J = 2 °C		COPd	
				T _J = 7 °C		COPd	
				T _J = 12 °C		COPd	
				T _J = Bivalent temperature		COPd	
				T _J = operating limit		COPd	
				T _J = -15 °C		COPd	
Bivalent temperature				operating limit			
heating / Average		T _{biv}		-7		°C	
heating / Warmer		T _{biv}		2		°C	
heating / Colder		T _{biv}				°C	
				heating / Average		T _{ol}	
				heating / Warmer		T _{ol}	
				heating / Colder		T _{ol}	
Cycling interval capacity				Cycling interval efficiency			
for cooling		P _{cycc}				kW	
for heating		P _{cyhc}				kW	
Degradation co-efficient cooling**		C _{dc}		0.25		-	
				for cooling		EER _{cycc}	
				for heating		COP _{cycc}	
				Degradation co-efficient cooling**		C _{dh}	
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode		P _{off}		0		kW	
Standby mode		P _{sb}		0		kW	
Thermostat-off mode		P _{TO}		0		kW	
Crankcase heater mode		P _{CK}		0		kW	
				Kühlung		Q _{CE}	
				heating / Average		Q _{HE}	
				heating / Warmer		Q _{HE}	
				heating / Colder		Q _{HE}	
Capacity control				Other items			
Fest		N		Sound power level (indoor/outdoor)		L _{WA}	
Gestaffelt		N		Global warming potential		GWP	
Variable		N		Rated air flow (indoor/outdoor)		-	
						57.0 / 59.0	
						db(A)	
						675.0	
						kgCO ₂ eq.	
						11.0 / 34.0	
						m ³ /min	
Contact details for obtaining more information				Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default C_d = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.