

Outdoor unit		RXM35R5V1B9					
Indoor unit		FDXM35F3V1B9					
Function				Heating season			
Kühlung		Ja		Average (mandatory)		Ja	
Heizen		Ja		Warmer (if designated)		Ja	
				Colder (if designated)		Nein	
Element		Symbol		Wert		Gerät	
Design Load				Seasonal efficiency			
Kühlung		P _{designc}		3.40		kW	
heating / Average		P _{designh}		2.90		kW	
heating / Warmer		P _{designh}		1.57		kW	
heating / Colder		P _{designh}		1.57		kW	
Declarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J				Declarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J			
T _J = 35 °C		P _{dc}		3.40		kW	
T _J = 30 °C		P _{dc}		2.50		kW	
T _J = 25 °C		P _{dc}		1.61		kW	
T _J = 20 °C		P _{dc}		1.46		kW	
T _J = 35 °C		EER _d		2.98		-	
T _J = 30 °C		EER _d		4.08		-	
T _J = 25 °C		EER _d		8.05		-	
T _J = 20 °C		EER _d		9.65		-	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C		P _{dh}		2.57		kW	
T _J = 2 °C		P _{dh}		1.57		kW	
T _J = 7 °C		P _{dh}		1.02		kW	
T _J = 12 °C		P _{dh}		1.19		kW	
T _J = Bivalent temperature		P _{dh}		2.57		kW	
T _J = operating limit		P _{dh}		2.15		kW	
T _J = -7 °C		COP _d		2.60		-	
T _J = 2 °C		COP _d		3.84		-	
T _J = 7 °C		COP _d		4.94		-	
T _J = 12 °C		COP _d		6.08		-	
T _J = Bivalent temperature		COP _d		2.60		-	
T _J = operating limit		COP _d		2.01		-	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = 2 °C		P _{dh}		1.57		kW	
T _J = 7 °C		P _{dh}		1.02		kW	
T _J = 12 °C		P _{dh}		1.19		kW	
T _J = Bivalent temperature		P _{dh}		1.57		kW	
T _J = operating limit		P _{dh}		2.15		kW	
T _J = 2 °C		COP _d		3.84		-	
T _J = 7 °C		COP _d		4.94		-	
T _J = 12 °C		COP _d		6.08		-	
T _J = Bivalent temperature		COP _d		3.84		-	
T _J = operating limit		COP _d		2.01		-	
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C		P _{dh}		-		kW	
T _J = 2 °C		P _{dh}		-		kW	
T _J = 7 °C		P _{dh}		-		kW	
T _J = 12 °C		P _{dh}		-		kW	
T _J = Bivalent temperature		P _{dh}		-		kW	
T _J = operating limit		P _{dh}		-		kW	
T _J = -15 °C		P _{dh}		-		kW	
T _J = -7 °C		COP _d		-		-	
T _J = 2 °C		COP _d		-		-	
T _J = 7 °C		COP _d		-		-	
T _J = 12 °C		COP _d		-		-	
T _J = Bivalent temperature		COP _d		-		-	
T _J = operating limit		COP _d		-		-	
T _J = -15 °C		COP _d		-		-	
Bivalent temperature				operating limit			
heating / Average		T _{biv}		-7		°C	
heating / Warmer		T _{biv}		2		°C	
heating / Colder		T _{biv}		-		°C	
heating / Average		T _{ol}		-15		°C	
heating / Warmer		T _{ol}		-15		°C	
heating / Colder		T _{ol}		-		°C	
Cycling interval capacity				Cycling interval efficiency			
for cooling		P _{cycc}		-		kW	
for heating		P _{cyhc}		-		kW	
Degradation co-efficient cooling**		C _{dc}		0.25		-	
for cooling		EER _{cycc}		-		-	
for heating		COP _{cycc}		-		-	
Degradation co-efficient cooling**		C _{dh}		0.25		-	
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode		P _{off}		0.014		kW	
Standby mode		P _{sb}		0.014		kW	
Thermostat-off mode		P _{TO}		0.007		kW	
Crankcase heater mode		P _{CK}		0		kW	
Kühlung		Q _{CE}		226		kWh/a	
heating / Average		Q _{HE}		1,046		kWh/a	
heating / Warmer		Q _{HE}		450		kWh/a	
heating / Colder		Q _{HE}		-		kWh/a	
Capacity control				Other items			
Fest		N		Sound power level (indoor/outdoor)		-WA 53.0 / 61.0 db(A)	
Gestaffelt		N		Global warming potential		GWP 675 kgCO ₂ eq.	
Variable		N		Rated air flow (indoor/outdoor)		- 8.7 / 36.0 m ³ /min	
Contact details for obtaining more information				Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default C_d = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.