

Outdoor unit		RZAG35A2V1B					
Indoor unit		FTXM50R2V1B					
<b>Function</b>				<b>Heating season</b>			
Kühlung	Ja			Average (mandatory)	Ja		
Heizen	Ja			Warmer (if designated)	Nein		
				Colder (if designated)	Nein		
<b>Element</b>	<b>Symbol</b>	<b>Wert</b>	<b>Maßeinheit</b>	<b>Element</b>	<b>Symbol</b>	<b>Wert</b>	<b>Maßeinheit</b>
<b>Design Load</b>				<b>Seasonal efficiency</b>			
Kühlung	P <sub>designc</sub>	3.50	kW	Kühlung	SEER	7.76	-
heating / Average	P <sub>designh</sub>	2.60	kW	heating / Average	SCOP / A	4.68	-
heating / Warmer	P <sub>designh</sub>		kW	heating / Warmer	SCOP / W		-
heating / Colder	P <sub>designh</sub>		kW	heating / Colder	SCOP / C		-
<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj</b>				<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj</b>			
Tj = 35 °C	P <sub>dc</sub>	3.50	kW	Tj = 35 °C	EERd	4.32	-
Tj = 30 °C	P <sub>dc</sub>	2.58	kW	Tj = 30 °C	EERd	6.15	-
Tj = 25 °C	P <sub>dc</sub>	1.80	kW	Tj = 25 °C	EERd	9.43	-
Tj = 20 °C	P <sub>dc</sub>	1.89	kW	Tj = 20 °C	EERd	12.41	-
<b>Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj</b>				<b>Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7 °C	P <sub>dh</sub>	2.30	kW	Tj = -7 °C	COPd	3.06	-
Tj = 2 °C	P <sub>dh</sub>	1.40	kW	Tj = 2 °C	COPd	4.76	-
Tj = 7 °C	P <sub>dh</sub>	1.42	kW	Tj = 7 °C	COPd	6.25	-
Tj = 12 °C	P <sub>dh</sub>	1.66	kW	Tj = 12 °C	COPd	7.58	-
Tj = Bivalent temperature	P <sub>dh</sub>	2.30	kW	Tj = Bivalent temperature	COPd	3.06	-
Tj = operating limit	P <sub>dh</sub>	3.03	kW	Tj = operating limit	COPd	2.37	-
<b>Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj</b>				<b>Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = 2 °C	P <sub>dh</sub>		kW	Tj = 2 °C	COPd		-
Tj = 7 °C	P <sub>dh</sub>		kW	Tj = 7 °C	COPd		-
Tj = 12 °C	P <sub>dh</sub>		kW	Tj = 12 °C	COPd		-
Tj = Bivalent temperature	P <sub>dh</sub>		kW	Tj = Bivalent temperature	COPd		-
Tj = operating limit	P <sub>dh</sub>		kW	Tj = operating limit	COPd		-
<b>Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj</b>				<b>Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7 °C	P <sub>dh</sub>		kW	Tj = -7 °C	COPd		-
Tj = 2 °C	P <sub>dh</sub>		kW	Tj = 2 °C	COPd		-
Tj = 7 °C	P <sub>dh</sub>		kW	Tj = 7 °C	COPd		-
Tj = 12 °C	P <sub>dh</sub>		kW	Tj = 12 °C	COPd		-
Tj = Bivalent temperature	P <sub>dh</sub>		kW	Tj = Bivalent temperature	COPd		-
Tj = operating limit	P <sub>dh</sub>		kW	Tj = operating limit	COPd		-
Tj = -15 °C	P <sub>dh</sub>		kW	Tj = -15 °C	COPd		-
<b>Bivalent temperature</b>				<b>operating limit</b>			
heating / Average	T <sub>biv</sub>	-7	°C	heating / Average	T <sub>ol</sub>	-20	°C
heating / Warmer	T <sub>biv</sub>		°C	heating / Warmer	T <sub>ol</sub>		°C
heating / Colder	T <sub>biv</sub>		°C	heating / Colder	T <sub>ol</sub>		°C
<b>Cycling interval capacity</b>				<b>Cycling interval efficiency</b>			
for cooling	P <sub>cycc</sub>		kW	for cooling	EER <sub>cycc</sub>		-
for heating	P <sub>cych</sub>		kW	for heating	COP <sub>cycc</sub>		-
Degradation co-efficient cooling**	C <sub>dc</sub>	0.25	-	Degradation co-efficient cooling**	C <sub>dh</sub>	0.25	-
<b>Electric power input in power models other than 'active mode'</b>				<b>Annual electricity consumption</b>			
Off mode	P <sub>off</sub>	0.001	kW	Kühlung	Q <sub>CE</sub>	158	kWh/a
Standby mode	P <sub>sb</sub>	0.001	kW	heating / Average	Q <sub>HE</sub>	778	kWh/a
Thermostat-off mode	P <sub>TO</sub>	0.013	kW	heating / Warmer	Q <sub>HE</sub>		kWh/a
Crankcase heater mode	P <sub>CK</sub>	0	kW	heating / Colder	Q <sub>HE</sub>		kWh/a
<b>Capacity control</b>				<b>Other items</b>			
Fest	N			Sound power level (indoor/outdoor)	L <sub>WA</sub>	58.0 / 62.0	db(A)
Gestaffelt	N			Global warming potential	GWP	675.0	kgCO <sub>2</sub> eq.
Variable	N			Rated air flow (indoor/outdoor)	-	15.8 / 55.1	m <sup>3</sup> /min
<b>Contact details for obtaining more information</b>		Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium					

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

\*\* if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.