

Außengerät		3MXM52A2V1B9					
Innengerät		CTXM15A5V1B,FTXM25A5V1B,FTXM35A5V1B					
Function				Heating season			
Kühlung		Ja		Average (mandatory)		Ja	
Heizen		Ja		Warmer (if designated)		Ja	
				Colder (if designated)		Nein	
Element	Symbol	Wert	Gerät	Element	Symbol	Wert	Gerät
Design Load				Seasonal efficiency			
Kühlung	P _{designc}	5.20	kW	Kühlung	SEER	8.51	-
heating / Average	P _{designh}	5.00	kW	heating / Average	SCOP / A	5.10	-
heating / Warmer	P _{designh}	2.70	kW	heating / Warmer	SCOP / W	6.52	-
heating / Colder	P _{designh}		kW	heating / Colder	SCOP / C		-
Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J				Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T_J			
T _J = 35 °C	P _{dc}	5.20	kW	T _J = 35 °C	EER _d	4.76	-
T _J = 30 °C	P _{dc}	3.84	kW	T _J = 30 °C	EER _d	7.19	-
T _J = 25 °C	P _{dc}	2.66	kW	T _J = 25 °C	EER _d	10.40	-
T _J = 20 °C	P _{dc}	2.05	kW	T _J = 20 °C	EER _d	12.48	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Average season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C	P _{dh}	4.43	kW	T _J = -7 °C	COP _d	3.30	-
T _J = 2 °C	P _{dh}	2.70	kW	T _J = 2 °C	COP _d	5.10	-
T _J = 7 °C	P _{dh}	1.74	kW	T _J = 7 °C	COP _d	6.53	-
T _J = 12 °C	P _{dh}	1.59	kW	T _J = 12 °C	COP _d	8.04	-
T _J = Bivalent temperature	P _{dh}	4.43	kW	T _J = Bivalent temperature	COP _d	3.30	-
T _J = operating limit	P _{dh}	4.10	kW	T _J = operating limit	COP _d	3.12	-
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = 2 °C	P _{dh}	2.70	kW	T _J = 2 °C	COP _d	5.10	-
T _J = 7 °C	P _{dh}	1.74	kW	T _J = 7 °C	COP _d	6.53	-
T _J = 12 °C	P _{dh}	1.59	kW	T _J = 12 °C	COP _d	8.04	-
T _J = Bivalent temperature	P _{dh}	2.70	kW	T _J = Bivalent temperature	COP _d	5.10	-
T _J = operating limit	P _{dh}	2.70	kW	T _J = operating limit	COP _d	5.10	-
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Colder season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C	P _{dh}		kW	T _J = -7 °C	COP _d		-
T _J = 2 °C	P _{dh}		kW	T _J = 2 °C	COP _d		-
T _J = 7 °C	P _{dh}		kW	T _J = 7 °C	COP _d		-
T _J = 12 °C	P _{dh}		kW	T _J = 12 °C	COP _d		-
T _J = Bivalent temperature	P _{dh}		kW	T _J = Bivalent temperature	COP _d		-
T _J = operating limit	P _{dh}		kW	T _J = operating limit	COP _d		-
T _J = -15 °C	P _{dh}		kW	T _J = -15 °C	COP _d		-
Bivalent temperature				operating limit			
heating / Average	T _{biv}	-7	°C	heating / Average	T _{ol}	-10	°C
heating / Warmer	T _{biv}	2	°C	heating / Warmer	T _{ol}	2	°C
heating / Colder	T _{biv}		°C	heating / Colder	T _{ol}		°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	P _{cycc}		kW	for cooling	EER _{cyc}		-
for heating	P _{cyhc}		kW	for heating	COP _{cyc}		-
Degradation co-efficient cooling**	C _{dc}	0.25	-	Degradation co-efficient cooling**	C _{dh}	0.25	-
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode	P _{off}	0.004	kW	Kühlung	Q _{CE}	214	kWh/a
Standby mode	P _{sb}	0.003	kW	heating / Average	Q _{HE}	1.373	kWh/a
Thermostat-off mode	P _{TO}	0	kW	heating / Warmer	Q _{HE}	580	kWh/a
Crankcase heater mode	P _{CK}	0	kW	heating / Colder	Q _{HE}		kWh/a
Capacity control				Other items			
Fest	N			Sound power level (indoor/outdoor)	L _{WA}	58.0 / 59.0	db(A)
Gestaffelt	N			Global warming potential	GWP	675	kgCO ₂ eq.
Variable	N			Rated air flow (indoor/outdoor)	-	11.9 / 11.9 / 13.2 / 42	m ³ /min
Contact details for obtaining more information				Dalkin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default C_d = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.